SHA850A&SHA860A MAP Function Operation Guide

December 16, 2025

Please follow the steps below to upgrade the firmware:

1. Download the firmware upgrade package from the official website.
2. Unzip the ADS format file and save it to the root directory of the U disk.
3. Insert the U disk into the USB Host port and navigate to **System > Service > Upgrade** on the device to locate the ADS file on the USB drive.
4. Confirm the analyzer will automatically perform the firmware upgrade.

Click to Download the complete Document

© 2021 SIGLENT TECHNOLOGIES

North American Headquarters

SIGLENT Technologies America, Inc
6557 Cochran Rd Solon, Ohio 44139
Tel: 440-398-5800
Toll Free:877-515-5551
Fax: 440-399-1211
info@siglent.com
www.siglentamerica.com/

European Sales Offices

SIGLENT TECHNOLOGIES EUROPE GmbH
Staetzlinger Str. 70
86165 Augsburg, Germany
Tel: +49(0)-821-666 0 111 0
Fax: +49(0)-821-666 0 111 22
info-eu@siglent.com
www.siglenteu.com

Asian Headquarters

SIGLENT TECHNOLOGIES CO., LTD.
Blog No.4 & No.5, Antongda Industrial Zone,
3rd Liuxian Road, Bao'an District,
Shenzhen, 518101, China.
Tel:+ 86 755 3661 5186
Fax:+ 86 755 3359 1582
sales@siglent.com
www.siglent.com/ens